

Certificate of Conformity

Certification No. : 13-34-047
Company Name : DK-LOK Corporation
Address : 7. Golden root-ro 129 beon-gil, Juchon-myeon,
Gimhae-si, Gyeongsangnam-do, South Korea
President : Eun-Sik, No
Item : Valves for Piping(27.4 MPa, CNG, Ball Valve)
Type(Model) : VC86B-F-8N-PK
Service Gas : CNG
A term of validity : March. 6. 2013. ~ March. 5. 2018.

| | | |
|---------|---------------------------|----------------------------------|
| Confirm | Inspector : Jong-Hwan, Oh | Technical manager : Gi-Hoi, Kim. |
|---------|---------------------------|----------------------------------|

This is to certify that the above item passed the type test in Article 17 of 『High Pressure Gas Safety Control Act』 or Article 20 of 『Liquefied Petroleum Gas Safety Control & Business Act』 .

Date Certified March. 6. 2013.

Korea Gas Safety Corporation

1390 Wonjung-ro Maengdong-myeon, Eumseong-gun, Chungcheongbuk-do, Korea
Tel : +82 43 750-1511 Fax : +82 43 750-1930



Test Report

| | |
|--------------------------------|---|
| Certification No. : | 13-34-047 |
| Method of Test | KGS AA331 : 2012 |
| Item | Valves for Piping(27.4 MPa, CNG, Ball Valve) |
| Model | VC86B-F-8N-PK |
| Manufacturing Nation / Company | KOREA / DK-LOK Corporation |
| Service Gas | CNG |
| Working Pressure | 27.4 MPa |
| Material of Body | ASTM A479 316 |
| Material of Cover | ASTM A276 316 |
| Material of Ball | ASTM A276 316 |
| Material of Seat | PEEK |
| Size | 15A(1/2") |
| End-to-End Dimension | (89.1 ± 0.5) mm |
| Valve Operating Type | Lever |
| End Connection Type(Inlet) | NPT |
| End Connection Type(Outlet) | NPT |
| Assembling of Body and Cover-1 | 3-Pieces |
| Assembling of Body and Cover-2 | Screw thread |
| Construction-1 | Reduced Bore |
| Construction-2 | Floating Type |
| Etc | Instrument, Control, Sampling Piping System Valve(MSS SP-99) |

- End of Informations -

Korea Gas Safety Corporation

1390 Wonjung-ro Maengdong-myeon, Eumseong-gun, Chungcheongbuk-do, Korea

Tel : +82 43 750-1511 Fax : +82 43 750-1930

